

# City of Wichita, Kansas

## Americans with Disabilities Act Transition Plan

### Fire Station #16

1632 N. Tyler

August 2005



**DMCG**  
**Disability Management Consulting Group L.L.C.**  
2801 Jonquil Place  
Columbia, MO 65202

In conjunction with

**The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board**

**City of Wichita – ADA/504 Transition Plan – Fire Station #16 - August 2005** Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations		Structural Inconsistencies	Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Restroom	Round door hardware exists on the entrance door to the men's and women's restroom.	<a href="#">4.13</a>	According to ADAAG, any doors used by the general public in existing buildings are required to have opening hardware, which does not require tight grasping or twisting of the wrist to operate. <b>Modify this door by replacing door knobs with lever-type hardware or installing add-on levers.</b>	L	M	M	<a href="#">1</a>	\$200	See Attachment B – <a href="#">Accessible Door Hardware</a> for information on inexpensive add-on lever handles.			
	All other aspects of this facility are fully accessible and in compliance with ADAAG specifications.											

**Fire Station #16 - Conceptual Cost Projections**

Total	\$200
Year Three (High)	\$0
Year Five (Medium)	\$0
Year Ten (Low)	\$200